



## City of Palm Springs Fire Department Regulations For Outdoor Events

Outdoor events involving street closures surrounding the Palm Springs Convention Center are subject to the following requirements:

- A 20 ft. wide, unobstructed fire lane shall be maintained at all times through the Event spaces which allows the passage of fire apparatus to respond to fires, medical aid calls, or other emergencies within the event space, around the exterior of the building and within the Palm Springs Convention Center.  
**Exception:** The area fronting the main entrance of the Palm Springs Convention Center on Calle Alvarado, between the bollards, has been pre-designated and approved for exemption of the fire lane requirement.
- Tents, EZ ups, booths, stages, vehicles, aircraft, or any other fixed display or item shall not obstruct fire hydrants, fire department connections, access driveways, or any other areas deemed by the Fire Marshal as a safety risk, or potential obstruction to fire suppression activities.
- Street closure barricades shall be staffed by security personnel at all times in order to open the fire lane access for emergency response vehicles.
- The above requirements shall be incorporated into the event diagram and submitted to the fire department 30 days prior to the event. All outdoor events are subject to fire department approval.